

Approval Number 241055052
Test Report: PB2024003091 & PB2024003090



31st October 2024

Polymelt GmbH
Kimachstrasse 17,
87640 Ebenhofen,
Germany

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE- COMPONENTS.

5260

'ECOSAN ML5 Pipe'. Extruded, multi-layered PP-RCT/PP-R/PP-R pipe which has a grey coloured inner layer and green coloured outer layer. The three intermediate layers are grey in colour.

'ECOSAN SDR6 Pipe'. Extruded, single layered, green coloured (with red external stripe) PP-R pipe.

Both pipes are for use with water up to 85°C.

APPROVAL NUMBER: 241055052

APPROVAL HOLDER: POLYMELT GMBH

The Scheme reserves the right to review approval.

Approval 241055052 is valid between October 2024 and October 2029

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrassapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes'.

Ian Hughes
WRAS Approvals Manager